



DEPARTMENT OF PUBLIC WORKS

5520 Churchman Ave. ♦ Beech Grove, IN 46107-2006
Office: 317.803.9092 ♦ Fax: 317.788.4983

Sanitation Department Report

January 7, 2013

1. Solid Waste Report from Covanta

January	Tons – 323.22	Price per Ton – 29.00	Total Bill – 9,373.38
February	Tons – 296.74	Price per Ton – 29.00	Total Bill – 8,605.46
March	Tons – 443.48	Price per Ton – 29.00	Total Bill – 12,860.92
April	Tons – 364.90	Price per Ton – 29.00	Total Bill – 10,582.10
May	Tons – 372.25	Price per Ton – 29.00	Total Bill – 10,795.25
June	Tons – 291.86	Price per Ton – 29.00	Total Bill – 8,463.94
July	Tons – 333.12	Price per Ton – 29.00	Total Bill – 9,660.48
August	Tons – 433.80	Price per Ton – 29.00	Total Bill – 12,580.20
September	Tons – 362.17	Price per Ton – 29.00	Total Bill – 10,502.93
October	Tons – 472.89	Price per Ton – 29.00	Total Bill – 13,713.81
November	Tons – 479.52	Price per Ton – 29.00	Total Bill – 13,906.08
December	Tons – 295.49	Price per Ton – 29.00	Total Bill – 8,569.21
YTD:	Tons – 4,469.44	Price per Ton – 29.00	Total Bill – 129,613.76

2. Ray's Trash Service – Recycling Update

Current number of households participating – 158

Anyone interested in signing up can contact Ray's Trash at (317) 539-2024 or visit www.raystrash.com.

3. Flow Meter Report

Total Amount Treated – 35,355,156 gallons

Monthly Precipitation – 2.58 inches

4. Monthly Holiday Trash Information

There was no trash pick up on Tuesday January 1st due to the New Year Holiday. DPW ran both Tuesday and Wednesday's trash routes on Wednesday January 2nd.

There are no other Holidays in January that impact the trash schedule.

5. Sanitary Sewer Report by Phil Gurganus

December 3, 2012

- A49 }
- A50 } cleaned sewer line at Grovewood and
- A51 } Emerson (Kentucky Fried Chicken and car wash)
- A52 } responded to sewer call at 181 N. 9th – normal flow
- D8 }

- A90 }
- A91 }
- A94 } cleaned sanitary sewer line in the 600 block of
- A101 } South 4th and over to Memorial
- A102 }

December 4, 2012

- A79 }
- A52 } checked two sanitary manholes for discharge pipe during rain event – normal flow, these were suspect due to recent smoke testing both appear to be abandoned and can be capped

- worked on clogged drain at 6th and Main (construction related)

December 5, 2012

- unclogged drain at 6th and Main where pipe was repaired by contractor – clogged with pit run sand
- worked on small drain at 8th and Main near Napoli Villa – appears to be blocked due to water main installation

- C26 } responded to sewer call at 139 S. 9th – jetted out unknown clog
- C27 } in main, flushed in both direction manhole to manhole
- cleaned nozzles on jet machine and cleaned water filter, bled air out of pump

December 6, 2012

- C26 } worked with Wessler Engineering using their pole camera
- C27 } to check defects in sewer segments between manholes
- C28 } **C26, C27, and C28**
- G45 } responded to sewer call at 279 Gilbert, checked manholes,
- G46 } **G45 and G46** – normal flow, resident’s lateral clogged
- B6A } checked 2 sanitary sewers at S. 9th and Fletcher – removed
- B5 } rags from channel – normal flow

December 10, 2012

- found and fixed oil leak on jet truck
- C51 }
- C52 } checked sanitary sewer in alley between S. 3rd and S. 4th
- C53 } Churchman to Main – normal flow
- C54 }
- cleaned leaves out of 3 curb outfalls at 5400 Churchman Avenue
- cleaned 3 storm sewer catch basins on Subway
- picked up litter dumped on Subway that would float down to basins
- cleaned 4 catch basins at 4th and Alton
- cleaned 1 catch basin at Garstang
- spoke with resident at 181 N. 9th about problems with his lateral

December 11, 2012

- put temporary plug in suspected abandoned force main in the manhole at 5600 Elmwood to check for flow (smoke testing required further investigation)
- F44 }
- F43 } checked 4 sanitary manholes on closed St. Francis facility –
- F52 } substantial flow still exists
- F54 }

- **F55** } cleaned up leaves at 11th and Main in the construction area
- } cleaned 2 catch basins on Main Street bridge over Lick Creek
- } checked additional manholes on St. Francis campus for flow –
- } 6 sanitary not on map – flow on most

- **C44** } checked sanitary sewer between S. 5th and S. 6th at Churchman
- } dead-end – no flow – normal

December 12, 2012

- **F89** }
- **554** }
- **A43** }
- **A79** }

- cleaned drains at 13th and Main and Lick Creek bridge after contractor had water valve break at the library
- worked installing metal brackets on concrete blocking of salt barn

December 13, 2012

- **D22** }
- **D23** }
- } responded to sewer call at 187 N. 8th
- } flushed main with jet to obstruction – 300 gallons of water
- } passed by lateral connection

- discussed sanitary sewer issues on St. Francis campus with Brad Robertson of Wessler Engineering
- prepared maps for sewer investigation planned for Monday at St. Francis campus

December 17, 2012

- **F45** }
- **F44** }
- **F43** }
- **F46** }
- **F48** }
- **F52** }
- **F56** }
- **F57** }
- **F58** }
- **F59** }
- **F55A** }

- } worked with Brad Robertson of Wessler Engineering to
- } record and document sewer flow from the St. Francis campus

- **C86** }
- **C88** }
- } responded to sewer call at 80 S. 12th and flushed main
- } behind home

December 18, 2012

- reviewed campus map of St. Francis and location of manholes
- refilled jet machine with water

December 20, 2012

- **F52** }
- **F55A** }
- **F56** } checked flows from St. Francis during rain (noted one pipe
- **F54** } running that was not during dry weather at manhole **F52**)
- **F89A** }

- cleaned 3 catch basins at Subway Street
- cleaned 3 catch basins at 2nd and Alton

- **C86** }
- **C88** } checked sanitary sewer manhole at 1250 Alton and
1250 Parkway

- **A79** } checked sanitary sewer manhole at 5600 Elmwood (no flow out
of suspect pipe)

December 31, 2012

- **H94** } checked manhole near 4830 S. Emerson (normal flow)

Sanitary Sewer Cleaning Report
City of Beech Grove
Department of Public Works

December 2012

Date	Location	Upstream Manhole	Downstream Manhole	Pipe Diameter	Pipe Material	Length
12/3/2012	Emerson at Grovewood Place	A51	A50	8"	PVC	140'
12/3/2012	Emerson at Park Emerson Drive	A52	A51	8"	PVC	94'
12/3/2012	Grovewood Place and Emerson	A50	A49	8"	PVC	34'
12/3/2012	500 Block of S. 4th	A103	A102	8"	VCP	228'
12/3/2012	600 Block of S. 4th	A102	A101	8"	VCP	207'
12/3/2012	600 Block of S. 4th	A101	A90	8"	VCP	220'
12/3/2012	S. 4th to Memorial	A94	A91	8"	VCP	143'
12/3/2012	S. 4th to Memorial	A91	A90	8"	VCP	143'
12/5/2012	Between S. 8th and S. 9th from Alton to Bellefontaine	C27	C26	8"	VCP	645'
12/13/2012	Between N. 8th and N. 7th South of Buffalo	D23	D22	8"	VCP	258'
12/17/2012	Alley between S. 12th and S. 13th from Parkway to Alton	C88	C86	8"	VCP	295'