



DEPARTMENT OF PUBLIC WORKS

5520 Churchman Ave. ♦ Indianapolis, IN 46203
Office: 317.803.9098 ♦ Fax: 317.788.4983

Sanitation Department Report

April 1, 2013

1. Solid Waste Report from Covanta

Table with 4 columns: Month, Tons, Price per Ton, Total Bill. Rows for January, February, March, and YTD.

2. Ray's Trash Service – Recycling Update

Current number of households participating – 153

Anyone interested in signing up can contact Ray's Trash at (317) 539-2024 or visit www.raystrash.com.

3. Flow Meter Report

Total Amount Treated – 66,351,900 gallons

Monthly Precipitation – 1.96 inches

4. Monthly Holiday Trash Information

There are no Holidays during the month of April that will impact the trash schedule.

5. Sanitary Sewer Report by Phil Gurganus

March 4

- A68}
➤ A69} Checked sanitary manholes on Elmwood Ave. – all flowing
➤ A70} normal.

- A71}
- A77}
- A79}

- Cleaned 4 catch basins at 10th and Main St.

March 5

- H4}
- H5}
- H8}
- H10}
- H11}
- H12}
- H13}

Checked sanitary manholes on North Bend – all flowing normal.

March 7

- G1}
- G2}
- G4}
- G5}
- G6}
- G9}
- G10}

Checked sanitary manholes on N. 25th – Royal Road to Southern Avenue – normal flows.

- Cleaned 3 catch basins on Subway St.

March 11

- C26}
- C27}
- C28}

Checked sanitary manholes in the area to be televised – all normal flows.

- Cleaned out 4 catch basins at 4th and Alton.

March 12

- F92}
- F95}
- F96}

Responded to sewer call at 353 N. 16th Ave. Checked 3 manholes. Main backed up – opened with jet machine.

March 13

- F96
- C26}
- C27}

Checked sanitary sewer serving N. 16th.
Checked sanitary manholes where commercial sewer had worked – all normal flows.

March 18

- Investigated drainage concern at 5345 Adelaide. Contracted English Excavating to get a quote for pipe replacement.

March 19

- G128 Checked sewer for 405 N. 20th.
- F95 Jetted line 300' – no obstructions.
- Checked sewer behind 353 N. 16th – clear and flowing.
- Received quote from English for Adelaide project.

March 20

- Checked storm sewer repair at 5345 Adelaide.

March 21

- C27} Jetted sewer in alley between S. 8th and 9th – Alton to
- C26} Bellefontaine.
- Added root inhibitor to storm sewers at S. 4th and Byland.

March 26

- G22}
 - G23} Checked sewer at 2215 Mann Drive. Main was backed up. Used
 - G24} jet machine to dislodge blockage of roots and rags. Probably
 - G25} rodded out of private line. Returned and removed more root balls
 - G26} that had washed downstream.
 - G27}
 - F92 Rechecked manhole behind 353 N. 16th – clear and flowing.
 - C28 Met with Commercial Sewer at manhole C28 in an attempt to
- televiser the line. Root cutter got stuck in offset – got cutter out and terminated the work.

March 27

- F98 Responded to sewer call at 261 N. 15th. Plumber requested we
- F99 flush main. Flushed main past lateral numerous times.
- Added rip rap to storm sewer pipe installed on Adelaide.

